

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106


1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## TEST REPORT

**Client :** Orafol Australia  
8 Blanck Street  
Ormeau QLD 4208

**Test Number :** 23-005064  
**Issue Date :** 19/12/2023  
**Print Date :** 19/12/2023

**Sample Description** Clients Ref : "Oraguard 210M Matt PVC Laminate"  
Self adhesive film  
Colour : Clear  
End Use : Floor Graphics



312260

68290

Page 1 of 2

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



Fiona McDonald

APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)  
MANAGING DIRECTOR

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## TEST REPORT

**Client :** Orafol Australia  
8 Blanck Street  
Ormeau QLD 4208

**Test Number :** 23-005064  
**Issue Date :** 19/12/2023  
**Print Date :** 19/12/2023

**AS 4586-2013**  
**Appendix A**

**Slip Resistance Classification of new Pedestrian Surface Materials**  
**Wet Pendulum Test Method**

Date of Testing 18-12-2023  
Operator AWTA Test Operator 4  
Test Temperature (20±5degC) 22 °C  
Sample mounted to aluminum plate prior testing  
Test Direction Length  
Fixed/Unfixed Unfixed

Slider No 96 Batch No 23

Length	1	2	3	4	5	SRV
British Pendulum number	34	34	35	35	34	34

Classification P2

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 11/10/2023  
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

Non Directional product  
Tested in long direction of submitted sample

312260

68290

Page 2 of 2

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



Fiona McDonald

APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)  
MANAGING DIRECTOR